



Underwriters Laboratories Inc.®

CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 090702 - E220921

ISSUE DATE: July 09, 2002

Page 1 of 2

Issued to: Danfoss Bauer GmbH
Eberhard-Bauer-Str 36-60
D-73734 Esslingen Germany

Report Reference: E220921, February 18, 2002

This is to Certify that representative samples of: System Components, Electrical Insulation.
Class 155 (F) Motor Insulation Systems designated GMT155.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1446 - Systems of Insulating Materials - General

Additional Information: See Addendum

Only those products bearing the UL Recognized Component Marking should be considered as being covered by UL's Recognition and Follow-Up Service.

The UL Recognized Component Marking generally consists of the manufacturer's identification and catalog number, model number, or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark: **RA**, may be used in conjunction with the required Recognized Markings. The Recognized Component Mark is required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual recognitions.

LOOK FOR THE UL RECOGNIZED COMPONENT MARKING ON THE PRODUCT

Engineer:
R. Prasad Ava/R
R. Prasad Ava - Associate Project Engineer
UL International Germany GmbH

Review Engineer:
A. J. Baig/R
A. J. Baig - Senior Project Engineer
UL International Germany GmbH

Pursuant to the Corporate Services Agreement between UL International Germany GmbH and Underwriters Laboratories Inc. ("UL"), UL hereby accepts and issues this Certificate of Compliance. For questions in Germany, you may call +49 6102 3690.



Underwriters Laboratories Inc.®

CERTIFICATE OF COMPLIANCE - ADDENDUM

CERTIFICATE NUMBER: 090702 - E220921


Page 2 of 2

ISSUE DATE: July 09, 2002

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UR requirements.

Ratings:

System Designation: GMT155
Insulation Class: 155(F)
Maximum Temperature: 155°C hot spot
Outdoor Indoor: Yes
Maximum (Enclosed): Yes
Voltage 600 V



Engineer:

R. Prasad Ava / R
R. Prasad Ava - Associate Project Engineer

Review Engineer:

A. J. Baig / R
A. J. Baig - Senior Project Engineer

Pursuant to the Corporate Services Agreement between UL International Germany GmbH and Underwriters Laboratories Inc. ("UL"), UL hereby accepts and issues this Certificate of Compliance.